

SARDAR PATEL BHAVN JILLA PANCHAYAT OFFICE
RAJMAHEL ROAD (6TH FLOOR HEALTH DEPARTMENT) - VADODARA
PHONE – 02652432383 Email-dsl.health.vadodara@gmail.com

No.Health /DSI/Sanitation/ ૧૭૪ /2026

DATE - 06 / 07 / 2026

To,

Managing Trustee,
OneWorld Baroda Public School,
Dist. Vadodara.

Subject: Opinion/Certificate of Health and Sanitation Facilities

In reference to your application, this is to certify that Dr. Hemsingh Rathore, D.Q.A.M.O. Vadodara conducted a personal inspection, at "OneWorld Baroda Public School", Survey No.352/B, Final Plot No.217, TP 42 (Koyali), Nr.Shivam Residency, Opp. Foodista Restaurant, Vill.Koyali, Dist.Vadodara – 391330 on dated 04/07/2026. The water test report for the collected sample (Ref: PHL/PW/0857/2026) is attached.

During the inspection, the following observations were made:

1. **Health and Cleanliness:** The health and cleanliness conditions of both the school premises and the school-going children are up to the standard.
2. **Drinking Water Facilities:** Clean, fresh, and safe chlorinated/R.O. drinking water facilities are available for the students.
3. **Sanitation and Environment:** A hygienic, clean, and environmentally safe sanitary condition is well maintained by the school management.

Based on these findings, this certificate is hereby issued.

Validity: This certificate is valid for a period of one (1) year from the date of issue.




Chief District Health Officer
District Panchayat, Vadodara



PUBLIC HEALTH LABORATORY

VADODARA MUNICIPAL CORPORATION

(NABL Accredited Testing Laboratory as per ISO/IEC 17025 : 2017)



Name and address of Customer (#):

ONE WORLD BARODA PUBLIC SCHOOL
SURVEY NO.352/B, FINAL PLOT NO.217, TP-42, KOYLI, OPP.
FOODISTA RESTAURANT, KOYLI, VADODARA - 391330

Test Report No : PHL/PW/0857/2026
Test Report Issue Date : 10-06-2026
Sample Code No. : PW/0839/2026
Sample Received Date : 05-06-2026
ULR Number : TC955926000002027F

Test Report

- (i) Kind of Sample (#) : Drinking Water (R.O.)
(ii) Sample Description : 1 litre water sample received in plastic bottle.
(iii) Sample Condition : Received in good condition.
(iv) Physical Appearance : A clear colourless liquid.
(v) Date of Performance : 05-06-2026 to 10-06-2026.
(vi) Location of Performance : Water Testing Lab.
(vii) Discipline : Chemical.
(viii) Group : Water.

Sr. No.	Quality Characteristic	Name of Method of Test Used	Result	IS 10500:2012 (2 nd Revision)	
				Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
1	Colour, Hazen unit	APHA (24 th Ed.2022), Method: 2120 B	1	Max.	Max.
2	Odour	IS 3025 (Part-5) : 2018	Agreeable	5	15
3	Turbidity, NTU	APHA (24 th Ed.2022), Method: 2130 B	0.14	Agreeable	Agreeable
4	pH at 25°C	APHA (24 th Ed.2022), Method: 4500 H ⁺ B	6.90	1	5
5	Conductivity at 25°C, µs/cm	APHA (24 th Ed.2022), Method: 2510 B	183.00	6.5 to 8.5	No relaxation
6	Total Dissolved Solids, mg/L	APHA (24 th Ed.2022), Method: 2540 C	110.00	-	-
7	Total Hardness (as CaCO ₃), mg/L	APHA (24 th Ed.2022), Method: 2340 C	86.00	500	2000
8	Calcium (as Ca ²⁺), mg/L	APHA (24 th Ed.2022), Method: 3500 Ca ²⁺ B	16.83	200	600
9	Magnesium (as Mg ²⁺), mg/L	APHA (24 th Ed.2022), Method: 3500 Mg ²⁺ B	10.67	75	200
10	Chloride (as Cl ⁻), mg/L	APHA (24 th Ed.2022), Method: 4500 Cl ⁻ B	30.00	30	100
11	Sulphate (as SO ₄ ²⁻), mg/L	APHA (24 th Ed.2022), Method: 4500 SO ₄ ²⁻ E	38.34	250	1000
12	Nitrate (as NO ₃ ⁻), mg/L	APHA (24 th Ed.2022), Method: 4500 NO ₃ ⁻ B	< 1.00	200	400
13	Fluoride (as F ⁻), mg/L	APHA (24 th Ed.2022), Method: 4500 F ⁻ C	< 0.10	45	No relaxation
14	Total Alkalinity (as CaCO ₃), mg/L	APHA (24 th Ed.2022), Method: 2320 B	< 0.10	1	1.5
			18.00	200	600

Note : Above tests are accredited by NABL

Opinion: In respect of test performed as above, the sample Complies with standard requirement of IS 10500 : 2012 (2nd revision) for drinking water.



(Signature)

(M. L. Patel)

Food Analyst

Public Health Laboratory

Vadodara Municipal Corporation

Note:

1. This Report is refers only to particular sample submitted for testing.
2. This Report is not to be used for the purpose of Advertisement or Legal action.
3. Information marked with "#" is provided by the customer.

****End of Test Report****

Office Address: 1st & 2nd Floor, Old Vuda Building, Fatehgunj, Vadodara - 390002

Telephone: 0265-2781433



PUBLIC HEALTH LABORATORY

VADODARA MUNICIPAL CORPORATION

Name and address of Customer (#):
ONE WORLD BARODA PUBLIC SCHOOL
SURVEY NO.352/B, FINAL PLOT NO.217, TP-42, KOYLI, OPP.
FOODISTA RESTAURANT, KOYLI, VADODARA - 391330

Test Report No : PHL/PW/0857/2026
Test Report Issue Date : 10-06-2026
Sample Code No. : PW/0839/2026
Sample Received Date : 05-06-2026

Test Report

- (i) Kind of Sample (#) : Drinking Water (R.O.)
(ii) Sample Description : 1 litre water sample received in plastic bottle.
(iii) Sample Condition : Received in good condition.
(iv) Physical Appearance : A clear colourless liquid.
(v) Date of Performance : 05-06-2026 to 10-06-2026.
(vi) Location of Performance : Water Testing Lab.
(vii) Discipline : Chemical and Biological.
(viii) Group : Water.

Sr. No.	Quality Characteristic	Name of Method of Test Used	Result	IS 10500:2012 (2nd Revision)	
				Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
				Max.	Max.
1	Residual Free Chlorine, mg/L	FSSAI Manual Method For Analysis of Foods (Water), 2016	Nil	0.2*	1.0
2	E. Coli	FSSAI Manual Method For Analysis of Foods (Water), 2016	Absent	shall not be detectable in any 100 ml sample	No relaxation

Note : Above tests are not accredited by NABL.

Opinion: In respect of test performed as above, the sample Complies with standard requirement of IS 10500 : 2012 (2nd revision) for drinking water.



(M. L. Patel)
Food Analyst
Public Health Laboratory
Vadodara Municipal Corporation

Note:

1. This Report is refers only to particular sample submitted for testing.
2. This Report is not to be used for the purpose of Advertisement or Legal action.
- 3*. To be applicable only when water is chlorinated.
- 4*. When protection against viral infection is required, it should be minimum 0.5 mg/L.
5. Information marked with "H" is provided by the customer.

****End of Test Report****